

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-0067:150

Page 1 of 2

CATEGORY: Control Unit (High Rise)

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Model "SYSTEM 3" fire alarm control unit. Unit is intended for use in conjunction with listee's Model VOICE ALARM SYSTEM (CSFM Listing no. 6911-0067:043) or EVAC System (CSFM Listing No. 6911-0067:149) to provide voice evacuation/communication, local, auxiliary, remote station (protected premises) or proprietary service. Refer to listee's data sheet and control unit's installation instructions for additional detailed product description and operational considerations. System components:

CP-30, -31, -35	Control Module
ZA-30 through -33, ZB-35, ZC-30, -31, ZH-30, -GD	Initiating Module
ZN-30 through -34, ZN-31U, -34US, ZU-35, -35DS	Initiating Module
ZU-35TS, MC-30	Initiating Module
AE-30, -30U, -31, AA-30, -30U	Alarm Module
SR-30, -32, -33, -35	Alarm Module
BC-30, -35, BE-35, BM-30, -31, TC-30U, DC-35S, PF-30	Power Supply Module
PS-3, -30, -31, -34, -35, -35S, DM-30R, MM-3RS	Power Supply Module
MM-30, -31, -32, -35	Power Supply Module
EA-30 through -35	Enclosure
PL-35	Power Limited Module
BI-35	Power Supply Interface
LP-30, MT-30	Remote Signal Panel
SR-30, -31, AC-30, -30U, TS-30, HS-30, HC-30U	Control Module
RM-30U, -30RU, DS-30, -31, RC-30, SA-30, AW-1, -2	Control Module
SM-30, -31, TL-30U, AD-30S, HC-35, CT-35, PM-31, -32	Control Module
QS-30	Linear Detection Cable

RATING: 120-240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, rating and UL label.

APPROVAL:

Listed as fire alarm control unit suitable for use in high-rise structures when used with voice EVAC system as described under "Design" and separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 10-26-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 26, 2002**

Listing Expires **June 30, 2003**

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager